



TEST RESULTS

16.0 SUMMARY OF RESULTS:

| Specimen #E1 | | |
|---|------------------------------------|--------------------|
| Test Method | Test Conditions | TEST RESULT |
| Air Infiltration Test (ASTM E283 and TAS 202) | 1.57 psf & 6.24 psf | PASS |
| Water Infiltration Test (ASTM E331 and TAS 202) | 15.0 psf | PASS |
| Uniform Static Load Test (ASTM E330 and TAS 202) | +70 / - 80 psf Design Pressure | PASS |
| Large Missile Impact Test (TAS 201 and ASTM E1886/E1996) | 9-lb 4-oz, 2 x 4 @ 50ft/sec | PASS |
| Cyclic Load Test (TAS 203 and ASTM E1996) | +70 / - 80 psf Design Pressure | PASS |
| Specimen #E2 | | |
| Large Missile Impact Test (TAS 201 and ASTM E1886/E1996) | 9-lb 4-oz, 2 x 4 @ 50ft/sec | PASS |
| Cyclic Load Test (TAS 203 and ASTM E1996) | +70 / - 80 psf Design Pressure | PASS |
| Specimen #E3 | | |
| Large Missile Impact Test (TAS 201 and ASTM E1886/E1996) | 9-lb 4-oz, 2 x 4 @ 50ft/sec | PASS |
| Cyclic Load Test (TAS 203 and ASTM E1996) | + 70 / - 80 psf Design Pressure | PASS |

ENGINEER OF RECORD


3/9/2007




TEST RESULTS

16.0 SUMMARY OF RESULTS

| Test Unit # E4 | | |
|---|-------------------------------|-----------------|
| Test Method | Test Conditions | Test Conclusion |
| Uniform Static Load Test (ASTM E330 and TAS 202) | +/- 60 psf Design Pressure | PASS |
| Large Missile Impact Test (TAS 201 and ASTM E1886/E1996) | 9-lb, 2 x 4 @ 50ft/sec | PASS |
| Cyclic Load Test (TAS 203 and ASTM E1996) | +/- 65 psf Design Pressure | PASS |
| Test Unit # E6 | | |
| Test Method | Test Conditions | Test Conclusion |
| Uniform Static Load Test (ASTM E330 and TAS 202) | +/- 60 psf Design Pressure | PASS |
| Large Missile Impact Test (TAS 201 and ASTM E1886/E1996) | 9-lb, 2 x 4 @ 50ft/sec | PASS |
| Cyclic Load Test (TAS 203 and ASTM E1996) | +/- 60 psf Design Pressure | PASS |

ENGINEER OF RECORD


3/9/2007