



August 24, 2007

FLORIDA | GEORGIA | TEXAS


CORPORATE HEADQUARTERS

6655 Garden Road  
Riviera Beach, Florida 33404  
HTLTEST.COM

Specimen #	Test Method	Test Conditions	Test Conclusion
E1	Air Infiltration Test (TAS 20 and ASTM E283)	1.57 & 6.24 psf	PASS
	Water Infiltration Test (TAS 202 and ASTM E331)	15 psf	PASS
	Static Load Test (TAS 203 and ASTM E330)	+70/-80 psf Design Pressure	PASS
	Large Missile Impact Test (TAS 201 and ASTM E1886/E1996)	9-lb. Wood 2 x 4 @ 50 ft/sec	PASS
	Cyclic Load Test (TAS 203 and ASTM E1886/E1996)	+70/-80 psf Design Pressure	PASS
E2	Large Missile Impact Test (TAS 201 and ASTM E1886/E1996)	9-lb. Wood 2 x 4 @ 50 ft/sec	PASS
	Cyclic Load Test (TAS 203 and ASTM E1886/E1996)	+70/-80 psf Design Pressure	PASS
E3	Large Missile Impact Test (TAS 201 and ASTM E1886/E1996)	9-lb. Wood 2 x 4 @ 50 ft/sec	PASS
	Cyclic Load Test (TAS 203 and ASTM E1886/E1996)	+70/-80 psf Design Pressure	PASS
E6	Static Load Test (TAS 203 and ASTM E330)	+60/-60 psf Design Pressure	PASS
	Large Missile Impact Test (TAS 201 and ASTM E1886/E1996)	9-lb. Wood 2 x 4 @ 50 ft/sec	PASS
	Cyclic Load Test (TAS 203 and ASTM E1886/E1996)	+60/-60 psf Design Pressure	PASS (Glass "IB" only)

Specimen #	Test Method	Test Conditions	Test Conclusion
E7	Static Load Test (TAS 203 and ASTM E330)	+70/-80 psf Design Pressure	PASS
	Large Missile Impact Test (TAS 201 and ASTM E1886/E1996)	9-lb. Wood 2 x 4 @ 50 ft/sec	PASS
	Cyclic Load Test (TAS 203 and ASTM E1886/E1996)	+70/-80 psf Design Pressure	PASS
E8	Static Load Test (TAS 203 and ASTM E330)	+70/-80 psf Design Pressure	PASS
	Large Missile Impact Test (TAS 201 and ASTM E1886/E1996)	9-lb. Wood 2 x 4 @ 50 ft/sec	PASS
	Cyclic Load Test (TAS 203 and ASTM E1886/E1996)	+70/-80 psf Design Pressure	PASS

HURRICANE TEST LABORATORY, LLC

  
José E. Colón, E.I.  
Operations Manager